

2720

8213 211TH PL SW

The City of Edmonds

APPLICATION

for
SIDE SEWER PERMIT

EASEMENT NO.

NEW CONSTRUCTION ☒

REPAIRS ☐

LID NO.

ASMT. NO.


OWNER BLOM THILSEN

CONTRACTOR B. & M. CONTRACTORS PERMIT NO. 66023

JOB ADDRESS 8213-21TH PL. S.W.

LEGAL DESCRIPTION: LOT NO. #9 BLOCK NO.

NAME OF ADDITION WOODLARK PARK



[Handwritten signature]

Approved:

DATE 11/20/12 By Mest. Roberts

NOTICE:

No warranty of accuracy.

The information shown on the attached map(s) was compiled for use by the City of Edmonds, its Employees and Consultants. The City of Edmonds does not warrant the accuracy of anything set forth on these map(s). Any person or entity requesting a copy should conduct an independent inquiry regarding the information shown on the map(s), including, but not limited to, the location of any sewer stub shown. Such sewer stubs may or may not exist and may or may not exist at the location shown. Neither the City of Edmonds nor its employees or officers shall be liable for the information given on map(s), nor for any one representation provided based upon said map(s).

CITY OF EDMONDS — SIDE SEWER PERMIT
WATER-SEWER DEPARTMENT

PERMIT NO. 0728

(Call 716-2525 for side sewer inspections BEFORE covering any portion of the construction.)
(Inspection will be provided within 24 hours after request. No Sat., Sun., or holiday inspections.)

ADDRESS LOCATION OF CONSTRUCTION 8213 211TH PL S.W.
PROPERTY LEGAL DESCRIPTION LOT #9 WOOD LAKE PARK

OWNER AND/OR BUILDER B & M

CONTRACTOR'S NAME & ADDRESS B & M
Permission is granted 2-2, 1978, for repair and/or connection of a side sewer to the city sanitary sewer system in accordance with City of Edmonds ordinances.

ATTENTION IS CALLED TO THE FOLLOWING:

NOTE No. 1.—The owners of the property may obtain a permit to construct sewer inside property line. A licensed Side Sewer Contractor must be employed to construct side sewer in street area. Do not cover any portion of sewer before it has been inspected.
NOTE No. 2.—All work performed in city right-of-way requires an Invasion of Right-of-Way Permit obtainable from the City Engineer's office.
NOTE No. 3.—Obtain full information regarding Ordinance 11.16.030 and Regulations governing side sewers when you get permit.
NOTE No. 4.—Top of side sewer must have at least 30 inches coverage at property line and 12 inches inside property line; minimum grade of 2%. No bends in grade sharper than 1/4 will be permitted.
NOTE No. 5.—Trenches in street must be water settled and surface of street restored to original condition. Contractors shall be responsible for failure due to improper work which may develop within one year of completion.
NOTE No. 6.—It is unlawful to alter or do any other work than is provided for in the permit, or to do any work on the main sewer or its appurtenances except to insert the pipe into the wye.

DISAPPROVED ☐ Date By Date By Date By

APPROVED ☒ Date May 27 1978 By [Signature] Date

Remarks: [Signature]

BOTH Permit Copies MUST Be Signed By Owner of Firm Performing Construction PRIOR To Request For Inspection —

I, [Signature], hereby certify that the side sewer installation constructed under this permit was installed in accordance with all governing ordinances of the City of Edmonds.

Dated this day of 19

✓✓ Check BEFORE you dig for: Water ☐ Gas ☐ Telephone ☐ Power ☐ Sewer ☐ Other ☐ ✓✓

The City of Edmonds

APPLICATION

for
SIDE SEWER PERMIT

EASEMENT NO.

NEW CONSTRUCTION ☐

REPAIRS ☐

LID NO.

ASMT. NO.

OWNER

BODEN THUESSEN

CONTRACTOR

B+M

PERMIT NO. 6023

JOB ADDRESS

8213-211TH PL SW

LEGAL DESCRIPTION: LOT NO.

#9

BLOCK NO.

NAME OF ADDITION

WOODLAKE PARK

121.47

26

78.18

13

21'10"

15'

38'

49.10

257

38.75

117.97

211 PL SW

Approved:

DATE

By

PUBLIC WORKS DEPARTMENT CHECKLIST

BUILDING PERMIT REVIEW

8213-211TH PLACE SW.

(address)

12/28/77

(date)

ENGINEERING	Street Right-of-Way Existing	40/40	REQD	N.A.
	Access Easements Existing	NONE	REQD	N.A.
	Utility Easement Existing	NONE	REQD	N.A.
	Lot Per Subdivision	—	Plat	X
	Assessor Map	—		
	Site Plan Checked for Accuracy	12/28/77		
	Underground Wiring Req.	YES		
WATER	Check Accuracy of Legal Description	12/28/77		
	Review by	B. Nino	Date	12/28/77
	Existing Water Main Size	6" DI		
	Water Main Required	NA		
	Service Line Required	3/4"		
	Hydrant Size Existing	0C		
	Hydrant Req. Per Fire Code	Size		
STORM SEWER	Detector Check Meter Req.	NO		
	Cross Connection Inspection	NO		
	Fire Department Comments			
	Water Meter Charge Req.	# 290.00		
	Review by	KKK	Date	12/28/77
	Septic Tank Design Approved	NA	Date	
	Septic Tank Permit Req.	NA	Permit No.	
	Sanitary Sewer Availability	Yes	Proj.	PLAT
	Drawing No.	6564	Legal & Assoc. Inc. File No.	
	Side Sewer Availability	TO PROPERTY LINE		
STORM SEWER	Sanitary Sewer Connection Fee Req.	NONE		
	Review by	KKK	Date	
	Open Ditch Existing	None	Req.	—
	Culvert Req.	None	Size	—
	Catch Basin Req.	None	Indicate on Site Plan	—
	Shoulder drainage maintain collection on swale open runoff	Roller curb		
	Manhole req.	None	Indicate on Site Plan	—
	Soil Conditions and Ground Water Field Checked	Chen		
	Review by	A. J. Blum	Date	12-28-77

8213-211th Pl. SW

*29000 ASI 5973

